



STS Directory

Accreditation number: STS 0210

International standard: ISO/IEC 17025:2017
Swiss standard: SN EN ISO/IEC 17025:2018

PIFFNER Instrument
Transformers Ltd.
Testing Laboratory
Lindenplatz 17
5042 Hirschthal

Head: Florian Elmiger
Responsible for MS: Stefan Gisy
Telephone: +41 62 739 28 28
E-Mail: florian.elmiger@pmw.ch
Internet: <http://www.pfiffner-group.com>
Initial accreditation: 11.01.1999
Current accreditation: 24.09.2020 to 23.09.2025
Scope of accreditation see: www.sas.admin.ch
(Accredited bodies)

Scope of accreditation as of 18.05.2022

Testing laboratory for instrument transformers and high voltage tests

Group of products or materials, field of activity	Principle of measurement ²⁾ (characteristics, measuring ranges, type of test)	Test methods, remarks (national, international standards, in-house test methods)
Instrument transformers Current transformers	All tests for $U_m \leq 550 \text{ kV}$ (external test: Short-time current test – not part of this accreditation)	IEC 61869-1 IEC 61869-2 EN 61869-1 EN 61869-2 IEEE C57.13 IEEE C57.13.5 CAN/CSA-C61869-1 CAN/CSA-C61869-2 AS 60044.1 ABNT NBR 6821 ABNT NBR 6856



STS Directory

Accreditation number: STS 0210

Group of products or materials, field of activity	Principle of measurement ²⁾ (characteristics, measuring ranges, type of test)	Test methods, remarks (national, international standards, in-house test methods)
Inductive voltage transformers	All tests for $U_m \leq 550$ kV	IEC 61869-1 IEC 61869-3 EN 61869-1 EN 61869-3 IEEE C57.13 IEEE C57.13.5 CAN/CSA-C61869-1 CAN/CSA-C61869-3 AS 60044.2 ABNT NBR 6855
Combined transformers	All tests for $U_m \leq 550$ kV (external test: Short-time current test- not part of this accreditation)	IEC 61869-1 IEC 61869-4 EN 61869-1 EN 61869-4 IEEE C57.13 IEEE C57.13.5 CAN/CSA-C61869-1 CAN/CSA-C61869-4 AS 60044.3
Capacitor voltage transformers	All tests for $U_m \leq 550$ kV	IEC 61869-1 IEC 61869-5 EN 61869-1 EN 61869-5 ANSI C93.1 CAN/CSA-C61869-1 CAN/CSA-C61869-5 AS 60044.5
Sensors		
Low-power passive voltage transformers	All tests for $U_m \leq 550$ kV	IEC 61869-1 IEC 61869-6 IEC 61869-11
Voltage transformers - / Voltage dividers for DC applications	All tests	IEC 61869-1 IEC 61869-6 IEC 61869-15
Bushings		
Insulated bushings for alternating voltages > 1 kV	All tests for $U_m \leq 550$ kV	IEC 60137 EN 60137
Procedure standards		
	Partial discharge measurement ≤ 700 kV (Peak/ $\sqrt{2}$), 50 – 120 Hz ≤ 230 kV (Peak/ $\sqrt{2}$), 16 ² / ₃ Hz ≤ 800 kV DC	IEC 60270



STS Directory

Accreditation number: STS 0210

Group of products or materials, field of activity	Principle of measurement ²⁾ (characteristics, measuring ranges, type of test)	Test methods, remarks (national, international standards, in-house test methods)
<p>Insulating oil</p>	<p>High voltage test techniques</p> <p>Tests with alternating voltage ≤ 700 kV (Peak/$\sqrt{2}$), 50 – 120 Hz ≤ 230 kV (Peak/$\sqrt{2}$), 16 ²/₃ Hz</p> <p>Tests with direct voltage ≤ 800 kV DC</p> <p>Tests with lightning-impulse voltage ≤ 1600 kV, 1,2 / 50 μs</p> <p>Tests with switching-impulse voltage ≤ 1250 kV, 250 / 2500 μs</p> <p>Wet tests ≤ 700 kV (Peak/$\sqrt{2}$), 50 – 120 Hz ≤ 1600 kV, 1,2 / 50 μs ≤ 1250 kV, 250 / 2500 μs ≤ 800 kV DC</p> <p>Puncture voltage test</p>	<p>IEC 60060-1 IEEE Std 4</p> <p>IEC 60156</p>

*) IEC 61869 replaces IEC 60044

In case of contradictions in the language versions of the directories, the German version shall apply.

* / * / * / * / *