



National Accreditation Board for Testing and Calibration Laboratories

SCOPE OF ACCREDITATION

Laboratory Name :

HIGH VOLTAGE TEST LABORATORY, PFIFFNER INSTRUMENT TRANSFORMERS PRIVATE LIMITED, G. NO. 176, 178/2, NASHIK, NASHIK, MAHARASHTRA, INDIA

Accreditation Standard

ISO/IEC 17025:2017

Certificate Number

TC-10216

Page No

1 of 7

Validity

12/01/2022 to 11/01/2024

Last Amended on

-

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
Permanent Facility				
1	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Chopped Impulse Voltage Withstand Test on Primary Terminals	IEC 61869-1 Cl. No. 7.4.1
2	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Chopped Impulse Voltage Withstand Test on Primary Terminals	IS 16227 (Part-1) Cl. No. 7.4.1
3	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Determination of Composite Error (CE)	IEC 61869-2 Cl. No. 7.2.6
4	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Determination of Composite Error (CE)	IS 16227 (Part-2) Cl. No. 7.2.6.203
5	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Determination of the Instrument Security factor (ISF)	IEC 61869-2 Cl. No. 7.2.6
6	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Determination of the Instrument Security factor (ISF)	IS 16227 (Part-2) Cl. No. 7.2.6.202
7	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Determination of the Secondary Winding resistance	IEC 61869-2 Cl. No. 7.3.201
8	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Determination of the Secondary Winding resistance	IS 16227 (Part-2) Cl. No.7.3.201
9	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Inter-turn Overvoltage Test-Metering/Protection	IEC 61869-2 Cl. No. 7.3.204
10	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Inter-turn Overvoltage Test-Metering/Protection	IEC 61869-2 Cl. No. 7.3.204
11	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Inter-turn Overvoltage Test-Metering/Protection	IS 16227 (Part-2) Cl. No. 7.3.204
12	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Inter-turn Overvoltage Test-Metering/Protection	IS 16227 (Part-2) Cl. No. 7.3.204
13	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IEC 61869-1 Cl. No. 7.2.3.2
14	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IEC 61869-1 Cl. No. 7.2.3.2
15	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IEC 60060-1 Cl. No. 7.3.1
16	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IEC 60060-1 Cl. No. 7.3.1
17	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IEC 60060-1 Cl. No. 7.3.1



National Accreditation Board for Testing and Calibration Laboratories

SCOPE OF ACCREDITATION

Laboratory Name :

HIGH VOLTAGE TEST LABORATORY, PFIFFNER INSTRUMENT TRANSFORMERS PRIVATE LIMITED, G. NO. 176, 178/2, NASHIK, NASHIK, MAHARASHTRA, INDIA

Accreditation Standard

ISO/IEC 17025:2017

Certificate Number

TC-10216

Page No

2 of 7

Validity

12/01/2022 to 11/01/2024

Last Amended on

-

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
18	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IEC 61869-1 Cl. No. 7.2.3.2
19	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IEC 61869-2 Cl. No. 7.2.3
20	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IEC 61869-2 Cl. No. 7.2.3
21	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IEC 61869-2 Cl. No. 7.2.3
22	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IS 16227 (Part-1) Cl. No. 7.2.3.2
23	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IS 16227 (Part-1) Cl. No. 7.2.3.2
24	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IS 16227 (Part-1) Cl. No. 7.2.3.2
25	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Measurement of Capacitance and Dielectric dissipation factor at ambient temperature	IEC 61869-1 Cl. No. 7.4.3
26	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Measurement of Capacitance and Dielectric dissipation factor at ambient temperature	IEC 61869-1 Cl. No. 7.4.3
27	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Measurement of Capacitance and Dielectric dissipation factor at ambient temperature	IS 16227 (Part-1) Cl. No. 7.4.3
28	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Measurement of Capacitance and Dielectric dissipation factor at ambient temperature	IS 16227 (Part-1) Cl. No. 7.4.3
29	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Partial Discharge Measurement	IEC 60270 Cl. No. 4.3
30	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Partial Discharge Measurement	IEC 61869-1 Cl. No. 7.3.2.2
31	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Partial Discharge Measurement	IS 16227 (Part-1) Cl. No. 7.3.2.2
32	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Power Frequency Voltage Withstand Test between sections	IEC 61869-1 Cl. No. 7.3.3
33	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Power Frequency Voltage Withstand Test between sections	IS 16227 (Part 1) Cl. No. 7.3.3



National Accreditation Board for Testing and Calibration Laboratories

SCOPE OF ACCREDITATION

Laboratory Name :

HIGH VOLTAGE TEST LABORATORY, PFIFFNER INSTRUMENT TRANSFORMERS PRIVATE LIMITED, G. NO. 176, 178/2, NASHIK, NASHIK, MAHARASHTRA, INDIA

Accreditation Standard

ISO/IEC 17025:2017

Certificate Number

TC-10216

Page No

3 of 7

Validity

12/01/2022 to 11/01/2024

Last Amended on

-

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
34	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Power Frequency Voltage Withstand test on Primary Terminal	IEC 60060-1 Cl. No. 6.3.1
35	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Power Frequency Voltage Withstand test on Primary Terminal	IEC 61869-1 Cl. No. 7.3.1
36	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Power Frequency Voltage Withstand test on Primary Terminal	IEC 61869-2 Cl. No. 7.3.1
37	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Power Frequency Voltage Withstand test on Primary Terminal	IS 16227 (Part-1) Cl. No. 7.3.1
38	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Power Frequency Voltage withstand Test on Secondary Terminals	IEC 61869-1 Cl. No. 7.3.4
39	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Power Frequency Voltage withstand Test on Secondary Terminals	IS 16227 (Part-1) Cl. No. 7.3.4
40	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Temperature-Rise Test	IEC 61869-1 Cl. No. 7.2.2
41	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Temperature-Rise Test	IEC 61869-1 Cl. No. 7.2.2
42	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Temperature-Rise Test	IEC 61869-2 Cl. No. 7.2.2
43	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Temperature-Rise Test	IEC 61869-2 Cl. No. 7.2.2
44	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Temperature-Rise Test	IS 16227 (Part-1) Cl. No. 7.2.2
45	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Temperature-Rise Test	IS 16227 (Part-1) Cl. No. 7.2.2
46	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Temperature-Rise Test	IS 16227 (Part-2) Cl. No. 7.2.2
47	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Temperature-Rise Test	IS 16227 (Part-2) Cl. No. 7.2.2
48	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Test for Accuracy- Phase Error	IEC 61869-1 Cl. No. 7.2.6 & Cl. No. 7.3.5
49	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Test for Accuracy- Phase Error	IEC 61869-2 Cl. No. 7.2.6 & Cl. No. 7.3.5
50	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Test for Accuracy- Phase Error	IS 16227 (Part-2) Cl. No. 7.2.6 Cl. No. 7.3.5



National Accreditation Board for Testing and Calibration Laboratories

SCOPE OF ACCREDITATION

Laboratory Name :

HIGH VOLTAGE TEST LABORATORY, PFIFFNER INSTRUMENT TRANSFORMERS PRIVATE LIMITED, G. NO. 176, 178/2, NASHIK, NASHIK, MAHARASHTRA, INDIA

Accreditation Standard

ISO/IEC 17025:2017

Certificate Number

TC-10216

Page No

4 of 7

Validity

12/01/2022 to 11/01/2024

Last Amended on

-

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
51	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Test for Accuracy- Ratio Error	IEC 61869-1 Cl. No. 7.2.6 & Cl. No. 7.3.5
52	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Test for Accuracy- Ratio Error	IEC 61869-2 Cl. No. 7.2.6 & Cl. No. 7.3.5
53	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Test for Accuracy- Ratio Error	IS 16227 (Part-2) Cl. No. 7.2.6 & Cl. No. 7.3.5
54	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Test for Rated knee point e.m.f. and exciting current at rated knee point e.m.f.	IEC 61869-2 Cl. No.7.3.203
55	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Test for Rated knee point e.m.f. and exciting current at rated knee point e.m.f.	IEC 61869-2 Cl. No.7.3.203
56	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Test for Rated knee point e.m.f. and exciting current at rated knee point e.m.f.	IS 16227 (Part-2) Cl. No.7.3.203
57	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Test for Rated knee point e.m.f. and exciting current at rated knee point e.m.f.	IS 16227 (Part-2) Cl. No.7.3.203
58	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Verification of Markings (and Polarity)	IEC 61869-1 Cl. No. 7.3.6
59	ELECTRICAL- INDUCTORS & TRANSFORMERS	Current Transformer (72.5kV to 420kV)	Verification of Markings (and Polarity)	IS 16227 (Part 1) Cl. No. 7.3.6
60	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Chopped Impulse Voltage Withstand Test on Primary Terminals	IEC 61869-1 Cl. No. 7.4.1
61	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Chopped Impulse Voltage Withstand Test on Primary Terminals	IEC 61869-1 Cl. No. 7.4.1
62	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Chopped Impulse Voltage Withstand Test on Primary Terminals	IS 16227 (Part-1) Cl. No. 7.4.1
63	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Chopped Impulse Voltage Withstand Test on Primary Terminals	IS 16227 (Part-1) Cl. No. 7.4.1
64	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IEC 60060-1 Cl. No. 7.3.1
65	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IEC 60060-1 Cl. No. 7.3.1
66	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IEC 60060-1 Cl. No. 7.3.1



National Accreditation Board for Testing and Calibration Laboratories

SCOPE OF ACCREDITATION

Laboratory Name :

HIGH VOLTAGE TEST LABORATORY, PFIFFNER INSTRUMENT TRANSFORMERS PRIVATE LIMITED, G. NO. 176, 178/2, NASHIK, NASHIK, MAHARASHTRA, INDIA

Accreditation Standard

ISO/IEC 17025:2017

Certificate Number

TC-10216

Page No

5 of 7

Validity

12/01/2022 to 11/01/2024

Last Amended on

-

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
67	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IEC 61869-1 Cl. No. 7.2.3.2
68	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IEC 61869-1 Cl. No. 7.2.3.2
69	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IEC 61869-1 Cl. No. 7.2.3.2
70	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IEC 61869-3 Cl. No. 7.2.3.2
71	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IEC 61869-3 Cl. No. 7.2.3.2
72	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IEC 61869-3 Cl. No. 7.2.3.2
73	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IS 16227 (Part-1) Cl. No. 7.2.3.2
74	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IS 16227 (Part-1) Cl. No. 7.2.3.2
75	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Lightning Impulse Voltage on Primary Terminals (Dry)	IS 16227 (Part-1) Cl. No. 7.2.3.2
76	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Measurement of Capacitance and Dielectric dissipation factor at ambient temperature	IEC 61869-1 Cl. No. 7.4.3
77	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Measurement of Capacitance and Dielectric dissipation factor at ambient temperature	IEC 61869-1 Cl. No. 7.4.3
78	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Measurement of Capacitance and Dielectric dissipation factor at ambient temperature	IS 16227 (Part-1) Cl. No. 7.4.3
79	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Measurement of Capacitance and Dielectric dissipation factor at ambient temperature	IS 16227 (Part-1) Cl. No. 7.4.3
80	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Partial Discharge Measurement	IEC 60270 Cl. No. 4.3
81	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Partial Discharge Measurement	IEC 61869-1 Cl. No. 7.3.2.2
82	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Partial Discharge Measurement	IEC 61869-3 Cl. No. 7.3.2.2
83	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Partial Discharge Measurement	IS 16227 (Part-1) Cl. No. 7.3.2.2



National Accreditation Board for Testing and Calibration Laboratories

SCOPE OF ACCREDITATION

Laboratory Name :

HIGH VOLTAGE TEST LABORATORY, PFIFFNER INSTRUMENT TRANSFORMERS PRIVATE LIMITED, G. NO. 176, 178/2, NASHIK, NASHIK, MAHARASHTRA, INDIA

Accreditation Standard

ISO/IEC 17025:2017

Certificate Number

TC-10216

Page No

6 of 7

Validity

12/01/2022 to 11/01/2024

Last Amended on

-

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
84	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Partial Discharge Measurement	IS 16227 (Part-3) Cl. No. 7.3.2
85	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Power Frequency Voltage Withstand test on Primary Terminal	IEC 60060-1 Cl. No. 6.3.1
86	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Power Frequency Voltage Withstand test on Primary Terminal	IEC 61869-1 Cl. No. 7.3.1
87	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Power Frequency Voltage Withstand test on Primary Terminal	IEC 61869-3 Cl. No. 7.3.1
88	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Power Frequency Voltage Withstand test on Primary Terminal	IS 16227 (Part-1) Cl. No. 7.3.1
89	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Power Frequency Voltage Withstand test on Secondary Terminals	IEC 61869-1 Cl. No. 7.3.4
90	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Power Frequency Voltage Withstand test on Secondary Terminals	IS 16227 (Part-1) Cl. No. 7.3.4
91	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Temperature-Rise Test	IEC 61869-1 Cl. No. 7.2.2
92	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Temperature-Rise Test	IEC 61869-1 Cl. No. 7.2.2
93	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Temperature-Rise Test	IEC 61869-3 Cl. No. 7.2.2
94	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Temperature-Rise Test	IEC 61869-3 Cl. No. 7.2.2
95	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Temperature-Rise Test	IS 16227 (Part-1) Cl. No. 7.2.2
96	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Temperature-Rise Test	IS 16227 (Part-1) Cl. No. 7.2.2
97	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Temperature-Rise Test	IS 16227 (Part-3) Cl. No. 7.3.2
98	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Temperature-Rise Test	IS 16227 (Part-3) Cl. No. 7.3.2
99	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Test for Accuracy- Phase Error	IEC 61869-1 Cl. No. 7.2.6 & Cl. No. 7.3.5
100	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Test for Accuracy- Phase Error	IEC 61869-3 Cl. No. 7.2.6 & Cl. No. 7.3.5



National Accreditation Board for Testing and Calibration Laboratories

SCOPE OF ACCREDITATION

Laboratory Name :

HIGH VOLTAGE TEST LABORATORY, PFIFFNER INSTRUMENT TRANSFORMERS PRIVATE LIMITED, G. NO. 176, 178/2, NASHIK, NASHIK, MAHARASHTRA, INDIA

Accreditation Standard

ISO/IEC 17025:2017

Certificate Number

TC-10216

Page No

7 of 7

Validity

12/01/2022 to 11/01/2024

Last Amended on

-

S.No	Discipline / Group	Materials or Products tested	Component, parameter or characteristic tested / Specific Test Performed / Tests or type of tests performed	Test Method Specification against which tests are performed and / or the techniques / equipment used
101	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Test for Accuracy- Phase Error	IS 16227 (Part-3) Cl. No. 7.2.6 & Cl. No. 7.3.5
102	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Test for Accuracy- Ratio Error	IEC 61869-1 Cl. No. 7.2.6 & Cl. No. 7.3.5
103	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Test for Accuracy- Ratio Error	IEC 61869-3 Cl. No. 7.2.6 & Cl. No. 7.3.5
104	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Test for Accuracy- Ratio Error	IS 16227 (Part-3) Cl. No. 7.2.6 & Cl. No. 7.3.5
105	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Verification of Markings (and Polarity)	IEC 61869-1 Cl. No. 7.3.6
106	ELECTRICAL- INDUCTORS & TRANSFORMERS	Inductive Voltage Transformer (72.5kV to 420kV)	Verification of Markings (and Polarity)	IS 16227 (Part 1) Cl. No. 7.3.6